

HEAT PUMPS

Equipped with the Award Winning **Comfort Control System™**



Rheem® Prestige® S E R I E S

- Increased Reliability
- On-Board Diagnostics
- Fault Recall
- *Active Protection™*



RPQL- JEZ

R-410A

15 SEER Models
Efficiencies up to 15.5 SEER/13 EER/10.45 HSPF
Nominal Sizes 1 1/2 to 5 Tons
[5.28 kW] to [17.6 kW]

Eight Models

Cooling Capacities
18,100 to 60,500 BTU/HR
[5.30 kW] to [17.73 kW]
HSPF up to 9.00




The Rheem *Prestige Series™* RPQL- JEZ Heat Pump Outdoor units can provide year-round heating and cooling comfort for residential, multi-family and light commercial applications. They are designed to operate with Rheem indoor units with cooling and heating capacities certified under the AHRI Certification program.

The following additional features, plus its energy-saving characteristics, make the RPQL- JEZ Heat Pump outdoor unit an excellent choice for new construction or upgrading your present system.

The Rheem *Prestige Series™* RPQL- JEZ Heat Pumps are the result of an ongoing development program for improved efficiencies. With SEER's up to 15.5, these units continue a tradition of high efficiency.

- The *Comfort Control System™* provides on-board diagnostics and fault history for heat pumps with single-phase compressors by detecting system and electrical problems without adding sensors. It can also communicate "fault codes" to enabled "L terminal" thermostats. The integrated diagnostics with *Active Protection* prevents compressor operation when potentially harmful conditions are detected.
- 7-Segment LED Display is exclusive only to Rheem products. The information-display quickly and accurately shows technicians the source of malfunctions.
- Features a five-year conditional unit replacement warranty when properly installed with a new Rheem Air Handler OR Rheem Indoor Coil with a Rheem Gas Furnace.
- Compressor sound blanket is standard to provide quiet operation.
- Attractive, louvered wrap around jacket protects coil from weather extremes and yard hazards. Top grille is steel reinforced for extra strength. Cabinet is powder painted for all weather protection.
- Four sided outdoor coil design allows compressor operation with access panel removed.
- Air is discharged upward away from bushes and shrubs. The discharge pattern of the top grille provides minimum air restriction, resulting in quiet fan operation.
- Combination Grille/Motor Mount secures the fan motor to the underside of the discharge grille.
- Removable top grille provides access to the outdoor fan motor and outdoor coil.
- Compressor compartment offers additional protection from the elements and reduces operating noise.
- Single speed, 8-pole fan motor is designed for quieter, energy-saving operation.
- Non-cycling reversing valve and demand defrost.
- All models meet or exceed a 1000-hour salt spray test per ASTM B117 Standard Practice for Operating Salt Spray Testing Apparatus.



"Proper sizing and installation of equipment is critical to achieve optimal performance. Split system air conditioners and heat pumps must be matched with appropriate coil components to meet ENERGY STAR criteria. Ask your Contractor for details or visit www.energystar.gov."

FEATURES & BENEFITS OF THE *COMFORT CONTROL SYSTEM*[™]

- The Rheem exclusive 7-Segment LED Display easily shows system operating status codes and diagnostic codes.

- A Sealed Switch replaces the standard




contactor and features optical control and latching mechanism. The sealed switch prevents infiltration of insects and dust. A minimal switching arc, by the optical control, offers greater reliability. The latching mechanism consumes less power while reducing chatter.



- The Status Indication and System Diagnostics feature thermostat communication capability, built-in diagnostics, high & low voltage monitoring and high & low pressure switch monitoring. The thermostat communication capability alerts the homeowner to any necessary service requirements. Faster, more accurate service is provided by the built-in diagnostics, by providing the HVAC professional with dependable information. With the high and low voltage monitoring feature, the control provides alerts for out-of-range conditions. In addition, high and low pressure-switch monitoring prevents the system from operating outside of its normal parameters.



- The fault recall feature will allow for the last six fault-codes to be displayed, and will retain these codes even if power failure occurs.
- Built-in short-cycle protection allows the compressor to restart easily without oil removal.
- A 30-second minimum run-time for every compressor call enables oil to return to the compressor.
- *Active Protection* monitors the system to prevent nuisance lockouts and prevents compressor operation when potentially harmful conditions are detected.
- The compressor and fan are controlled independently, which reduces the starting load and light dimming.
- A manual push-button is offered to operate the compressor and fan for 5 seconds to allow for an operation check.
- In order to save time and money, replacement automotive fuses can be utilized instead of replacing the entire control board.




STANDARD FEATURES

RPQL- JEZ Heat Pump Outdoor Units

1. Scroll compressor is hermetically sealed and incorporates internal high temperature motor overload protection, and durable insulation on the motor windings. It is externally mounted on rubber grommets to reduce vibration and noise.
2. **Enhanced Compressor Protection**—Features an **enhanced defrost control, auto-reset high pressure control, and auto-reset low pressure control** to provide compressor protection under abnormally high head pressure conditions (outdoor fan failure, restriction, dirty coil, etc.) or abnormally low suction pressure conditions (restrictions, TEV failure, loss of charge, indoor blower failure, etc.) while eliminating nuisance tripping sometimes experienced with conventional control systems.
3. Compressors have an internal pressure relief assembly to protect against excessive pressure differential.
4. All refrigerant connections are on the exterior of the unit, located close to the ground for neat appearing installations.
5. Cabinet is constructed of powder painted galvanized steel. The full wrap-around louvered grille protects the coil from damage.
6. Enhanced compressor sound blanket is standard.
7. **Demand Defrost Control**—Provides complete defrost when defrost is required.
8. **Non-Cycling Reversing Valve**—Eliminates discharge noises on each heating cycle.
9. **Hot Gas Muffler**—Reduces noise in heating cycle.
10. **Bi-Directional Filter Drier**—Standard on RPQL- JEZ models (shipped – not installed).
11. **Service valves** are standard on all models.
12. **Refrigerant Metering**—TEV accurately meters refrigerant into indoor and outdoor coils.
13. Copper tube—aluminum fin coils are used on all models.
14. The control box is located in the top corner of the cabinet providing for easy access through a service panel.
15. Service valves are standard on all models.
16. Field connections for power and control wiring are kept separate.
17. Every unit is factory charged and run-tested.
18. Separate compressor compartment for easy service access.
19. Drawn, painted basepan for extra corrosion resistance and sound reduction.
20. The **RPQL- JEZ** has a 10 year limited compressor warranty, plus a 5 year conditional unit replacement warranty. See General Terms of Limited Warranty for more details.
21. **Hard Start Kits**—Standard on all JEZ models.
22. Control Box Cover.

Problem-Solving Accuracy



SCROLL[®] COMPRESSOR

The scroll compressor is the key to efficiency for this Rheem model. It's the latest in high-efficiency compressor technology. The advanced scroll compressor offers low noise and vibration characteristics and features tolerance to liquid refrigerant and system contamination. The scroll compressor also has low start torque, eliminating start problems in the field. And its unique design enables the RPQL- JEZ Heat Pump to perform efficiently, quietly and dependably.

Model Number Identification

R	P	Q	L	—	018	J	E	Z
RHEEM	REMOTE HEAT PUMP	Q = 15 SEER	DESIGN SERIES L = R-410A		COOLING CAPACITY	ELECTRICAL DESIGNATION	VARIATIONS E = EQUIPPED WITH THE COMFORT CONTROL SYSTEM™	COOLING CONNECTION FITTING Z = SWEAT W/SCROLL
					018 = 18,000 BTU/HR [5.28 kW] 024 = 24,000 BTU/HR [7.03 kW] 030 = 30,000 BTU/HR [8.79 kW] 036/037 = 36,000 BTU/HR [10.55 kW] 042 = 42,000 BTU/HR [12.31 kW] 048 = 48,000 BTU/HR [14.07 kW] 056 = 56,000 BTU/HR [16.41 kW] 060 = 60,000 BTU/HR [17.58 kW]	J = 208/230V-1-60		

[] Designates Metric Conversions

Field Installed Accessories

- **Low Ambient Control**—Allows low temperature operation in the cooling cycle down to 0°F [-17.8°C] outdoor temperature. It is recommended that this control be installed in units to be operated for cooling at outdoor ambient temperatures under 70°F [21°C]. (Model No. RXAD-A08)
- **Thermostats**
 - **Compressor Crankcase Heater**—Available through PROSTOCK®.
 - **Thermostats and Subbases**—Available through PROSTOCK®.
 - **Blower Time Delay Control**—RXMD-C04.
 - **Fossil Fuel Kits**—RXPF-01
RXPF-02



200-Series *
Programmable



300-Series *
Deluxe Programmable

400-Series *
Special Applications/
Programmable



500-Series *
Communicating/
Programmable

Brand	Descriptor (3 Characters)	Series (3 Characters)	System (2 Characters)	Type (2 Characters)
RHC	- TST	213	UN	MS
RHC=Rheem	TST=Thermostat	200=Programmable 300=Deluxe Programmable 400=Special Applications/ Programmable 500=Communicating/ Programmable	GE=Gas/Electric UN=Universal (AC/HP/GE) MD=Modulating Furnace DF=Dual Fuel CM=Communicating	SS=Single-Stage MS=Multi-Stage

* Photos are representative. Actual models may vary.

For detailed thermostat match-up information, see specification sheet form number T11-001.

Rheem Heat Pump System

More than a reverse cycle air conditioner, it's a specially designed combination Winter/Summer comfort system using a single indoor coil for heating and cooling.

For all season home comfort, performance and energy conservation, choose a Rheem RPQL- JEZ Heat Pump and a RHSL, RHLL, or RHKL Series Air Handler.

To choose an Air Handler designed for use with the RPQL- JEZ Heat Pump, refer to the Performance Data Tables and/or the air handler specification sheet.

Performance Data AHRI Standard Conditions—RPQL- JEZ

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)					
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF	
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP		
Rev. 5/4/2012	RHLL-HM2417(RCSL-H*2417) ①	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	13.00	15.50	70	650 [307]	17,200 [5.0]	3.96	10,500 [3.1]	2.54	9.00	
	RCFL-H*2414	18,200 [5.3]	13,900 [4.1]	4,300 [1.3]	11.00	13.50	70	650 [307]	16,600 [4.9]	4.10	9,900 [2.9]	2.59	8.50	
	RCFL-H*2417	18,200 [5.3]	13,900 [4.1]	4,300 [1.3]	11.00	13.50	70	650 [307]	16,600 [4.9]	4.10	9,900 [2.9]	2.59	8.50	
	RCFL-H*2417(RGFE-06?MCK?)	18,300 [5.4]	13,800 [4.0]	4,500 [1.3]	12.50	15.00	70	575 [271]	16,900 [5.0]	3.92	10,100 [3.0]	2.49	9.00	
	RCFL-H*2417(RGFE-07?MCK?)	18,500 [5.4]	14,100 [4.1]	4,400 [1.3]	12.50	15.00	70	600 [283]	16,900 [5.0]	3.92	10,100 [3.0]	2.49	9.00	
	RCFL-H*2417(RGFG-06?MCK?)	18,300 [5.4]	13,800 [4.0]	4,500 [1.3]	12.50	15.00	70	575 [271]	16,900 [5.0]	3.92	10,100 [3.0]	2.49	9.00	
	RCFL-H*2417(RGFG-07?MCK?)	18,400 [5.4]	14,000 [4.1]	4,400 [1.3]	12.50	15.00	70	600 [283]	16,900 [5.0]	3.91	10,100 [3.0]	2.49	9.00	
	RCFL-H*2417(RGGE-06?MCK?)	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	13.00	15.50	70	625 [295]	16,900 [5.0]	3.92	10,100 [3.0]	2.50	9.00	
	RCFL-H*2417(RGGE-07?MCK?)	18,300 [5.4]	13,800 [4.0]	4,500 [1.3]	12.50	15.00	70	575 [271]	16,800 [4.9]	3.93	10,100 [3.0]	2.50	9.00	
	RCFL-H*2417(RGJF-06?MCK?)	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	13.00	15.50	70	625 [295]	16,900 [5.0]	3.92	10,100 [3.0]	2.50	9.00	
018JEZ	RCFL-H*2417(RGJF-07?MCK?)	18,300 [5.4]	13,800 [4.0]	4,500 [1.3]	12.50	15.00	70	575 [271]	16,800 [4.9]	3.93	10,100 [3.0]	2.50	9.00	
	RCFL-H*2417(RGLE-07?AMK?)	18,500 [5.4]	14,100 [4.1]	4,400 [1.3]	13.00	15.50	70	600 [283]	16,800 [4.9]	3.94	10,100 [3.0]	2.51	9.00	
	RCFL-H*2417(RGLT-07?AMK?)	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	13.00	15.50	70	675 [319]	16,900 [5.0]	3.91	10,100 [3.0]	2.49	9.00	
	RCFL-H*2417(RGPE-05?BMK?)	18,300 [5.4]	13,800 [4.0]	4,500 [1.3]	12.50	15.00	70	575 [271]	16,900 [5.0]	3.92	10,100 [3.0]	2.49	9.00	
	RCFL-H*2417(RGPE-07?AMK?)	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	13.00	15.50	70	625 [295]	16,800 [4.9]	3.93	10,100 [3.0]	2.50	9.00	
	RCFL-H*2417(RGPT-05?BMK?)	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	12.50	15.00	70	650 [307]	16,900 [5.0]	3.88	10,200 [3.0]	2.47	9.00	
	RCFL-H*2417(RGPT-07?AMK?)	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	13.00	15.50	70	625 [295]	16,900 [5.0]	3.91	10,100 [3.0]	2.49	9.00	
	RCFL-H*2417(RGRM-04?MAE?)	18,300 [5.4]	13,800 [4.0]	4,500 [1.3]	12.50	15.00	70	575 [271]	16,900 [5.0]	3.89	10,200 [3.0]	2.48	9.00	
	RCFL-H*2417(RGRM-06?MAE?)	18,400 [5.4]	14,000 [4.1]	4,400 [1.3]	12.50	15.00	70	600 [283]	16,900 [5.0]	3.90	10,100 [3.0]	2.49	9.00	
	RCFL-H*2417(RGRM-07?MAE?)	18,600 [5.4]	14,300 [4.2]	4,300 [1.3]	12.50	15.00	70	625 [295]	17,000 [5.0]	3.84	10,200 [3.0]	2.45	9.00	
	RCFL-H*2417(RGTM-06?MAE?)	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	13.00	15.50	70	625 [295]	16,900 [5.0]	3.90	10,200 [3.0]	2.48	9.00	
	RCFL-H*2417(ROCA-070E03)	18,500 [5.4]	14,100 [4.1]	4,400 [1.3]	13.00	15.50	70	600 [283]	16,800 [4.9]	3.94	10,100 [3.0]	2.50	9.00	
	RCFL-H*2417(ROLA-070E03)	18,400 [5.4]	14,000 [4.1]	4,400 [1.3]	12.50	15.00	70	600 [283]	16,900 [5.0]	3.89	10,200 [3.0]	2.48	9.00	
	RHKL-HM2417(RCSL-H*2417)	18,700 [5.5]	14,400 [4.2]	4,300 [1.3]	13.00	15.50	70	650 [307]	16,900 [5.0]	3.91	10,100 [3.0]	2.49	9.00	
	RHSL-HM1817(RCSL-H*2417)	18,100 [5.3]	13,700 [4.0]	4,400 [1.3]	11.50	14.00	70	600 [283]	17,200 [5.0]	3.68	10,500 [3.1]	2.37	8.50	
	024JEZ	RHLL-HM2417(RCSL-H*2417) ①	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.72	13,900 [4.1]	2.44	9.00
		RCFL-H*2414	23,600 [6.9]	17,550 [5.1]	6,050 [1.8]	11.50	14.00	70	800 [378]	23,600 [6.9]	3.48	14,500 [4.2]	2.30	8.50
		RCFL-H*2417	23,600 [6.9]	17,550 [5.1]	6,050 [1.8]	11.50	14.00	70	800 [378]	23,600 [6.9]	3.48	14,500 [4.2]	2.30	8.50
RCFL-H*2417(RGFE-06?MCK?)		24,000 [7.0]	18,000 [5.3]	6,000 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.68	14,000 [4.1]	2.42	9.00	

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
									BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*2417(RGFE-07?MCK?)	23,600 [6.9]	17,350 [5.1]	6,250 [1.8]	12.50	15.00	70	725 [342]	23,000 [6.7]	3.70	13,900 [4.1]	2.44	8.50
	RCFL-H*2417(RGFG-06?MCK?)	24,000 [7.0]	18,000 [5.3]	6,000 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.68	14,000 [4.1]	2.42	9.00
	RCFL-H*2417(RGFG-07?MCK?)	24,000 [7.0]	18,000 [5.3]	6,000 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.68	13,900 [4.1]	2.44	9.00
	RCFL-H*2417(RGGE-06?MCK?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	825 [389]	23,000 [6.7]	3.68	13,900 [4.1]	2.44	9.00
	RCFL-H*2417(RGGE-07?MCK?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.68	13,900 [4.1]	2.42	9.00
	RCFL-H*2417(RGJF-06?MCK?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	825 [389]	23,000 [6.7]	3.68	13,900 [4.1]	2.44	9.00
	RCFL-H*2417(RGJF-07?MCK?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.68	13,900 [4.1]	2.44	9.00
	RCFL-H*2417(RGLE-07?AMK?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.72	13,900 [4.1]	2.44	9.00
	RCFL-H*2417(RGLT-07?AMK?)	24,200 [7.1]	18,300 [5.4]	5,900 [1.7]	12.50	15.00	70	850 [401]	23,000 [6.7]	3.68	14,000 [4.1]	2.42	9.00
	RCFL-H*2417(RGPE-05?BMK?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.68	13,900 [4.1]	2.44	9.00
	RCFL-H*2417(RGPE-07?AMK?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	825 [389]	23,000 [6.7]	3.70	13,900 [4.1]	2.44	9.00
	RCFL-H*2417(RGPT-05?BMK?)	24,200 [7.1]	18,300 [5.4]	5,900 [1.7]	12.50	14.50	70	850 [401]	23,200 [6.8]	3.64	14,000 [4.1]	2.40	8.50
	RCFL-H*2417(RGPT-07?AME?)	24,200 [7.1]	18,300 [5.4]	5,900 [1.7]	12.50	15.00	70	850 [401]	23,000 [6.7]	3.66	14,000 [4.1]	2.42	9.00
	RCFL-H*2417(RGPT-07?AMK?)	24,200 [7.1]	18,300 [5.4]	5,900 [1.7]	12.50	15.00	70	850 [401]	23,000 [6.7]	3.66	14,000 [4.1]	2.42	9.00
	RCFL-H*2417(RGRM-04?MAE?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.00	14.50	70	800 [378]	23,200 [6.8]	3.64	14,000 [4.1]	2.40	8.50
	RCFL-H*2417(RGRM-06?MAE?)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.00	14.50	70	825 [389]	23,200 [6.8]	3.64	14,000 [4.1]	2.40	8.50
	RCFL-H*2417(RGRM-07?MAE?)	24,000 [7.0]	18,150 [5.3]	5,850 [1.7]	11.50	14.00	70	850 [401]	23,200 [6.8]	3.58	14,200 [4.2]	2.36	8.50
	RCFL-H*2417(RGTM-06?MAE?)	23,800 [7.0]	17,600 [5.2]	6,200 [1.8]	12.50	15.00	70	750 [354]	23,000 [6.7]	3.74	13,800 [4.0]	2.46	9.00
	RCFL-H*2417(RHWP-04WMX36A)	24,000 [7.0]	17,900 [5.2]	6,100 [1.8]	12.50	15.00	70	825 [389]	22,600 [6.6]	3.62	13,500 [4.0]	2.35	8.50
	RCFL-H*2417(ROCA-070E03)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.70	13,900 [4.1]	2.44	9.00
RCFL-H*2417(ROCA-070E04)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.70	13,900 [4.1]	2.44	9.00	
RCFL-H*2417(ROLA-070E03)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.70	13,900 [4.1]	2.44	9.00	
RCFL-H*2417(ROLA-070E04)	24,000 [7.0]	17,950 [5.3]	6,050 [1.8]	12.50	15.00	70	800 [378]	23,000 [6.7]	3.70	13,900 [4.1]	2.44	9.00	
RHKL-HM2417(RCSL-H*2417)	24,200 [7.1]	18,300 [5.4]	5,900 [1.7]	13.00	15.00	70	850 [401]	23,000 [6.7]	3.68	13,900 [4.1]	2.42	9.00	
RHSL-HM2417(RCSL-H*2417)	23,800 [7.0]	17,800 [5.2]	6,000 [1.8]	11.50	14.00	70	800 [378]	23,400 [6.9]	2.52	14,300 [4.2]	2.34	8.50	
030JEZ	RHLL-HM3617(RCSL-H*3617) ①	30,000 [8.8]	21,850 [6.4]	8,150 [2.4]	13.00	15.50	71	1,000 [472]	29,000 [8.5]	3.80	18,200 [5.3]	2.56	9.00
	RCFL-H*3617	29,400 [8.6]	21,200 [6.2]	8,200 [2.4]	11.50	14.00	71	1,000 [472]	27,600 [8.1]	3.25	17,000 [5.0]	2.00	8.20
	RCFL-H*3617(RGFE-06?MCK?)	29,600 [8.7]	21,600 [6.3]	8,000 [2.3]	12.00	14.50	71	1,000 [472]	28,600 [8.4]	3.48	17,900 [5.2]	2.18	8.50
	RCFL-H*3617(RGFE-07?MCK?)	29,600 [8.7]	21,600 [6.3]	8,000 [2.3]	11.50	14.00	71	1,025 [484]	28,600 [8.4]	3.46	17,900 [5.2]	2.16	8.20

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*3617(RGFG-06?MCK?)	29,600 [8.7]	21,600 [6.3]	8,000 [2.3]	12.00	14.50	71	1,000 [472]	28,600 [8.4]	3.48	17,900 [5.2]	2.18	8.50
	RCFL-H*3617(RGFG-07?MCK?)	29,600 [8.7]	21,600 [6.3]	8,000 [2.3]	11.50	14.00	71	1,000 [472]	28,600 [8.4]	3.46	17,900 [5.2]	2.17	8.20
	RCFL-H*3617(RGGE-06?MCK?)	29,600 [8.7]	21,200 [6.2]	8,400 [2.5]	12.50	15.00	71	925 [437]	28,400 [8.3]	3.58	17,600 [5.2]	2.22	9.00
	RCFL-H*3617(RGGE-07?MCK?)	29,800 [8.7]	21,600 [6.3]	8,200 [2.4]	12.00	14.50	71	1,025 [484]	28,600 [8.4]	3.50	17,800 [5.2]	2.18	8.50
	RCFL-H*3617(RGJF-06?MCK?)	29,600 [8.7]	21,200 [6.2]	8,400 [2.5]	12.50	15.00	71	925 [437]	28,400 [8.3]	3.58	17,600 [5.2]	2.22	9.00
	RCFL-H*3617(RGJF-07?MCK?)	29,800 [8.7]	21,600 [6.3]	8,200 [2.4]	12.00	14.50	71	1,025 [484]	28,600 [8.4]	3.50	17,800 [5.2]	2.18	8.50
	RCFL-H*3617(RGLE-07?AMK?)	29,800 [8.7]	21,800 [6.4]	8,000 [2.3]	12.50	15.00	71	1,025 [484]	28,400 [8.3]	3.53	17,700 [5.2]	2.20	9.00
	RCFL-H*3617(RGLT-07?AMK?)	29,800 [8.7]	21,400 [6.3]	8,400 [2.5]	12.50	15.00	71	925 [437]	28,200 [8.3]	3.63	17,500 [5.1]	2.25	9.00
	RCFL-H*3617(RGPE-05?BMK?)	29,400 [8.6]	21,000 [6.2]	8,400 [2.5]	12.50	15.00	71	900 [425]	28,200 [8.3]	3.56	17,600 [5.2]	2.22	9.00
	RCFL-H*3617(RGPE-07?AMK?)	29,400 [8.6]	21,000 [6.2]	8,400 [2.5]	12.50	15.00	71	900 [425]	28,200 [8.3]	3.58	17,500 [5.1]	2.22	9.00
030JEZ	RCFL-H*3617(RGPT-07?AMK?)	30,000 [8.8]	22,100 [6.5]	7,900 [2.3]	12.00	14.50	71	1,050 [495]	29,200 [8.6]	3.72	18,500 [5.4]	2.50	9.00
	RCFL-H*3617(RGRM-04?MAE?)	29,400 [8.6]	21,000 [6.2]	8,400 [2.5]	11.50	14.00	71	925 [437]	28,400 [8.3]	3.51	17,800 [5.2]	2.20	8.20
	RCFL-H*3617(RGRM-06?MAE?)	29,600 [8.7]	21,600 [6.3]	8,000 [2.3]	12.00	14.50	71	1,000 [472]	28,600 [8.4]	3.46	17,900 [5.2]	2.17	8.50
	RCFL-H*3617(RGRM-07?MAE?)	29,400 [8.6]	21,000 [6.2]	8,400 [2.5]	11.50	14.00	71	950 [448]	28,600 [8.4]	3.45	18,000 [5.3]	2.17	8.20
	RCFL-H*3617(RGTM-06?MAE?)	29,400 [8.6]	21,000 [6.2]	8,400 [2.5]	12.50	15.00	71	900 [425]	28,200 [8.3]	3.57	17,600 [5.2]	2.23	9.00
	RCFL-H*3617(RHWB-04WMX36A)	29,800 [8.7]	21,700 [6.4]	8,100 [2.4]	12.50	15.00	71	1,025 [484]	28,400 [8.3]	3.63	17,800 [5.2]	2.41	8.50
	RCFL-H*3617(RHWB-06WMX48A)	29,600 [8.7]	21,300 [6.2]	8,300 [2.4]	12.50	15.00	71	950 [448]	28,400 [8.3]	3.67	17,600 [5.2]	2.44	8.50
	RCFL-H*3617(ROCA-070E03)	29,800 [8.7]	21,800 [6.4]	8,000 [2.3]	12.50	15.00	71	1,000 [472]	28,400 [8.3]	3.53	17,700 [5.2]	2.20	9.00
	RCFL-H*3617(ROCA-070E04)	29,800 [8.7]	21,800 [6.4]	8,000 [2.3]	12.50	15.00	71	1,000 [472]	28,400 [8.3]	3.53	17,700 [5.2]	2.20	9.00
	RCFL-H*3617(ROLA-070E03)	29,600 [8.7]	21,000 [6.2]	8,600 [2.5]	12.50	15.00	71	900 [425]	28,200 [8.3]	3.60	17,500 [5.1]	2.23	9.00
	RCFL-H*3617(ROLA-070E04)	29,600 [8.7]	21,000 [6.2]	8,600 [2.5]	12.50	15.00	71	900 [425]	28,200 [8.3]	3.60	17,500 [5.1]	2.23	9.00
	RCFL-H*3621	29,400 [8.6]	21,200 [6.2]	8,200 [2.4]	11.50	14.00	71	1,000 [472]	27,600 [8.1]	3.25	17,000 [5.0]	2.00	8.20
	RCFL-H*3621(RGFE-06?MCK?)	29,800 [8.7]	21,600 [6.3]	8,200 [2.4]	12.00	14.50	71	1,000 [472]	28,600 [8.4]	3.49	17,800 [5.2]	2.17	8.50
	RCFL-H*3621(RGFE-07?MCK?)	29,600 [8.7]	21,600 [6.3]	8,000 [2.3]	12.00	14.50	71	1,025 [484]	28,600 [8.4]	3.47	17,900 [5.2]	2.17	8.50
	RCFL-H*3621(RGFE-09?ZCM?)	29,800 [8.7]	21,800 [6.4]	8,000 [2.3]	12.50	15.00	71	975 [460]	28,200 [8.3]	3.54	17,500 [5.1]	2.20	9.00
	RCFL-H*3621(RGFE-10?ZCM?)	30,000 [8.8]	21,800 [6.4]	8,200 [2.4]	12.50	15.00	71	1,000 [472]	28,400 [8.3]	3.55	17,600 [5.2]	2.20	9.00
	RCFL-H*3621(RGFG-06?MCK?)	29,800 [8.7]	21,600 [6.3]	8,200 [2.4]	12.00	14.50	71	1,000 [472]	28,600 [8.4]	3.49	17,800 [5.2]	2.17	8.50
	RCFL-H*3621(RGFG-07?MCK?)	29,600 [8.7]	21,600 [6.3]	8,000 [2.3]	12.00	14.50	71	1,000 [472]	28,600 [8.4]	3.47	17,900 [5.2]	2.17	8.50
RCFL-H*3621(RGFG-09?ZCM?)	29,800 [8.7]	21,800 [6.4]	8,000 [2.3]	12.50	15.00	71	975 [460]	28,200 [8.3]	3.54	17,500 [5.1]	2.20	9.00	

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*3621(RGTM-07?RBG?)	29,800 [8.7]	21,400 [6.3]	8,400 [2.5]	12.50	15.00	71	950 [448]	28,200 [8.3]	3.58	17,500 [5.1]	2.22	9.00
	RCFL-H*3621(RGTM-09?ZAJ?)	30,000 [8.8]	21,800 [6.4]	8,200 [2.4]	12.50	15.00	71	975 [460]	28,200 [8.3]	3.58	17,500 [5.1]	2.22	9.00
	RCFL-H*3621(RHWB-04WMX36A)	29,800 [8.7]	21,700 [6.4]	8,100 [2.4]	12.50	15.00	71	1,025 [484]	28,400 [8.3]	3.63	17,800 [5.2]	2.41	8.50
	RCFL-H*3621(RHWB-06WMX48A)	30,000 [8.8]	21,900 [6.4]	8,100 [2.4]	12.50	15.00	71	975 [460]	28,400 [8.3]	3.68	17,600 [5.2]	2.44	8.50
	RCFL-H*3621(ROCA-070E03)	30,000 [8.8]	21,800 [6.4]	8,200 [2.4]	12.50	15.00	71	1,000 [472]	28,400 [8.3]	3.54	17,600 [5.2]	2.20	9.00
	RCFL-H*3621(ROCA-070E04)	30,000 [8.8]	21,800 [6.4]	8,200 [2.4]	12.50	15.00	71	1,000 [472]	28,400 [8.3]	3.54	17,600 [5.2]	2.20	9.00
	RCFL-H*3621(ROLA-070E03)	29,600 [8.7]	21,000 [6.2]	8,600 [2.5]	12.50	15.00	71	900 [425]	28,200 [8.3]	3.61	17,500 [5.1]	2.24	9.00
	RCFL-H*3621(ROLA-070E04)	30,000 [8.8]	21,800 [6.4]	8,200 [2.4]	12.50	15.00	71	1,025 [484]	28,400 [8.3]	3.55	17,600 [5.2]	2.20	9.00
	RCFL-H*3621(ROLA-115E05)	30,200 [8.8]	22,200 [6.5]	8,000 [2.3]	12.50	15.00	71	1,050 [495]	28,400 [8.3]	3.53	17,700 [5.2]	2.20	9.00
	RHKL-HM3617(RCSL-H*3617)	30,000 [8.8]	21,800 [6.4]	8,200 [2.4]	12.50	15.00	71	1,025 [484]	28,200 [8.3]	3.55	17,600 [5.2]	2.22	9.00
RHSL-HM3017(RCSL-H*3617)	29,400 [8.6]	21,400 [6.3]	8,000 [2.3]	11.50	14.00	71	1,000 [472]	28,600 [8.4]	3.45	17,900 [5.2]	2.16	8.20	
036JEZ	RHLL-HM3617(RCSL-H*3617) ①	36,000 [10.5]	26,400 [7.7]	9,700 [2.8]	12.50	15.00	74	1,200 [566]	37,000 [10.8]	4.00	24,000 [7.0]	2.80	9.00
	RCFL-H*3617	34,800 [10.2]	24,500 [7.2]	10,300 [3.0]	11.50	14.00	74	1,075 [507]	36,200 [10.6]	3.90	23,200 [6.8]	2.70	8.20
	RCFL-H*3617(RGFE-06?MCK?)	35,400 [10.4]	25,700 [7.5]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.80	24,600 [7.2]	2.68	8.50
	RCFL-H*3617(RGFG-06?MCK?)	35,400 [10.4]	25,700 [7.5]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.80	24,600 [7.2]	2.68	8.50
	RCFL-H*3617(RGGE-06?MCK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,400 [11.0]	3.86	24,400 [7.1]	2.72	8.50
	RCFL-H*3617(RGGE-07?MCK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.84	24,600 [7.2]	2.72	8.50
	RCFL-H*3617(RGJF-06?MCK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,400 [11.0]	3.86	24,400 [7.1]	2.72	8.50
	RCFL-H*3617(RGJF-07?MCK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.84	24,600 [7.2]	2.72	8.50
	RCFL-H*3617(RGLE-07?AMK?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.92	24,400 [7.1]	2.76	8.50
	RCFL-H*3617(RGLT-07?AMK?)	35,800 [10.5]	25,900 [7.6]	9,900 [2.9]	12.50	15.00	74	1,150 [543]	36,200 [10.6]	3.94	23,200 [6.8]	2.74	8.50
	RCFL-H*3617(RGPE-05?BMK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.86	24,400 [7.1]	2.72	8.50
	RCFL-H*3617(RGPE-07?AMK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,225 [578]	37,400 [11.0]	3.88	24,400 [7.1]	2.72	8.50
	RCFL-H*3617(RGPT-05?BMK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,175 [554]	37,600 [11.0]	3.84	24,600 [7.2]	2.70	8.50
	RCFL-H*3617(RGPT-07?AMK?)	35,800 [10.5]	25,900 [7.6]	9,900 [2.9]	12.50	15.00	74	1,150 [543]	37,000 [10.8]	3.98	24,000 [7.0]	2.80	8.50
	RCFL-H*3617(RGRM-04?MAE?)	36,000 [10.5]	27,050 [7.9]	8,950 [2.6]	11.50	14.00	74	1,200 [566]	37,800 [11.1]	3.78	25,000 [7.3]	2.68	8.50
	RCFL-H*3617(RGRM-06?MAE?)	35,400 [10.4]	25,700 [7.5]	9,700 [2.8]	11.50	14.00	74	1,175 [554]	37,800 [11.1]	3.80	24,800 [7.3]	2.68	8.50
	RCFL-H*3617(RGTM-06?MAE?)	35,200 [10.3]	25,000 [7.3]	10,200 [3.0]	12.00	14.50	74	1,075 [507]	37,200 [10.9]	3.98	24,200 [7.1]	2.80	8.50
RCFL-H*3617(RHWB-04WMX36A)	36,400 [10.7]	26,300 [7.7]	10,100 [3.0]	12.00	14.50	74	1,150 [543]	37,600 [11.0]	3.98	24,600 [7.2]	2.81	8.50	

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*3617(RHWB-06WMX48A)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	37,800 [11.1]	3.95	24,800 [7.3]	2.80	8.50
	RCFL-H*3617(ROCA-070E03)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.90	24,400 [7.1]	2.74	8.50
	RCFL-H*3617(ROCA-070E04)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.90	24,400 [7.1]	2.74	8.50
	RCFL-H*3617(ROLA-070E03)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.50	15.00	74	1,175 [554]	37,200 [10.9]	3.96	24,200 [7.1]	2.78	8.50
	RCFL-H*3617(ROLA-070E04)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.50	15.00	74	1,175 [554]	37,200 [10.9]	3.96	24,200 [7.1]	2.78	8.50
	RCFL-H*3621	34,800 [10.2]	24,500 [7.2]	10,300 [3.0]	11.50	14.00	74	1,075 [507]	36,200 [10.6]	3.90	23,200 [6.8]	2.70	8.20
	RCFL-H*3621(RGFE-06?MCK?)	35,400 [10.4]	25,700 [7.5]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.82	24,600 [7.2]	2.70	8.50
	RCFL-H*3621(RGFE-09?ZCM?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,200 [10.9]	3.94	24,200 [7.1]	2.76	8.50
	RCFL-H*3621(RGFE-10?ZCM?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	12.00	14.50	74	1,225 [578]	37,400 [11.0]	3.92	24,400 [7.1]	2.76	8.50
	RCFL-H*3621(RGFG-06?MCK?)	35,400 [10.4]	25,700 [7.5]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.82	24,600 [7.2]	2.70	8.50
	RCFL-H*3621(RGFG-09?ZCM?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,200 [10.9]	3.94	24,200 [7.1]	2.76	8.50
	RCFL-H*3621(RGFG-10?ZCM?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.92	24,200 [7.1]	2.76	8.50
	RCFL-H*3621(RGGE-06?MCK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.88	24,400 [7.1]	2.74	8.50
	RCFL-H*3621(RGGE-07?MCK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.86	24,600 [7.2]	2.72	8.50
	RCFL-H*3621(RGGE-09?ZCM?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.50	15.00	74	1,225 [578]	37,200 [10.9]	3.96	24,200 [7.1]	2.78	8.50
	RCFL-H*3621(RGGE-10?ZCM?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,200 [10.9]	3.94	24,200 [7.1]	2.78	8.50
	RCFL-H*3621(RGJF-06?MCK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.88	24,400 [7.1]	2.74	8.50
	RCFL-H*3621(RGJF-07?MCK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.86	24,600 [7.2]	2.72	8.50
	RCFL-H*3621(RGJF-09?ZCM?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.50	15.00	74	1,225 [578]	37,200 [10.9]	3.96	24,200 [7.1]	2.78	8.50
	RCFL-H*3621(RGJF-10?ZCM?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,200 [10.9]	3.94	24,200 [7.1]	2.78	8.50
RCFL-H*3621(RGLE-07?AMK?)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.92	24,200 [7.1]	2.76	8.50	
RCFL-H*3621(RGLE-07?BRQ?)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,225 [578]	37,200 [10.9]	3.98	24,000 [7.0]	2.80	8.50	
RCFL-H*3621(RGLE-10?BRM?)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	13.00	15.50	74	1,200 [566]	36,400 [10.7]	3.96	23,400 [6.9]	2.76	8.50	
RCFL-H*3621(RGLT-07?AMK?)	35,800 [10.5]	25,900 [7.6]	9,900 [2.9]	12.50	15.00	74	1,150 [543]	36,200 [10.6]	3.94	23,200 [6.8]	2.74	8.50	
RCFL-H*3621(RGLT-07?BRQ?)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,200 [566]	37,200 [10.9]	3.98	24,200 [7.1]	2.80	8.50	
RCFL-H*3621(RGLT-10?BRM?)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,175 [554]	36,200 [10.6]	3.90	23,200 [6.8]	2.70	8.50	
RCFL-H*3621(RGPE-05?BMK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,400 [11.0]	3.88	24,400 [7.1]	2.72	8.50	
RCFL-H*3621(RGPE-07?AMK?)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	12.00	14.50	74	1,225 [578]	37,400 [11.0]	3.90	24,400 [7.1]	2.74	8.50	
RCFL-H*3621(RGPE-07?BRQ?)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,225 [578]	36,200 [10.6]	3.92	23,200 [6.8]	2.72	8.50	

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*3621(RGPE-10?BRM?)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,225 [578]	36,200 [10.6]	3.92	23,200 [6.8]	2.72	8.50
	RCFL-H*3621(RGPT-05?BMK?)	35,200 [10.3]	25,000 [7.3]	10,200 [3.0]	12.00	14.50	74	1,075 [507]	37,200 [10.9]	3.96	24,200 [7.1]	2.78	8.20
	RCFL-H*3621(RGPT-07?AMK?)	35,800 [10.5]	25,900 [7.6]	9,900 [2.9]	12.50	15.00	74	1,150 [543]	36,200 [10.6]	3.90	23,200 [6.8]	2.70	8.50
	RCFL-H*3621(RGPT-07?BRQ?)	36,800 [10.8]	27,700 [8.1]	9,100 [2.7]	12.50	15.00	74	1,325 [625]	36,200 [10.6]	3.92	23,200 [6.8]	2.72	8.50
	RCFL-H*3621(RGPT-10?BRM?)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,175 [554]	36,200 [10.6]	3.94	23,200 [6.8]	2.72	8.50
	RCFL-H*3621(RGRM-04?MAE?)	35,400 [10.4]	25,700 [7.5]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,800 [11.1]	3.78	24,800 [7.3]	2.66	8.50
	RCFL-H*3621(RGRM-06?MAE?)	35,400 [10.4]	25,700 [7.5]	9,700 [2.8]	11.50	14.00	74	1,175 [554]	37,800 [11.1]	3.80	24,800 [7.3]	2.68	8.50
	RCFL-H*3621(RGRM-09?ZAJ?)	35,200 [10.3]	25,000 [7.3]	10,200 [3.0]	12.50	15.00	74	1,075 [507]	36,200 [10.6]	3.90	23,200 [6.8]	2.70	8.50
	RCFL-H*3621(RGRM-10?ZAJ?)	35,600 [10.4]	25,700 [7.5]	9,900 [2.9]	12.00	14.50	74	1,150 [543]	37,200 [10.9]	3.94	24,200 [7.1]	2.76	8.50
	RCFL-H*3621(RGTM-06?MAE?)	35,200 [10.3]	25,000 [7.3]	10,200 [3.0]	12.50	15.00	74	1,075 [507]	36,200 [10.6]	3.90	23,200 [6.8]	2.70	8.50
	RCFL-H*3621(RGTM-07?RBG?)	35,600 [10.4]	25,600 [7.5]	10,000 [2.9]	12.50	15.00	74	1,125 [531]	36,200 [10.6]	3.94	23,200 [6.8]	2.74	8.50
	RCFL-H*3621(RGTM-09?ZAJ?)	35,600 [10.4]	25,500 [7.5]	10,100 [3.0]	12.50	15.00	74	1,100 [519]	36,400 [10.7]	3.98	23,400 [6.9]	2.76	8.50
	RCFL-H*3621(RHWB-04WMX36A)	36,400 [10.7]	26,300 [7.7]	10,100 [3.0]	12.00	14.50	74	1,150 [543]	37,600 [11.0]	3.98	24,600 [7.2]	2.82	8.50
	RCFL-H*3621(RHWB-06WMX48A)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	37,800 [11.1]	3.95	24,800 [7.3]	2.80	8.50
	RCFL-H*3621(ROCA-070E03)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.92	24,400 [7.1]	2.76	8.50
	RCFL-H*3621(ROCA-070E04)	35,800 [10.5]	26,100 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,400 [11.0]	3.92	24,400 [7.1]	2.76	8.50
	RCFL-H*3621(ROLA-070E03)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,175 [554]	37,200 [10.9]	3.98	24,000 [7.0]	2.80	8.50
	RCFL-H*3621(ROLA-070E04)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,175 [554]	37,200 [10.9]	3.98	24,000 [7.0]	2.80	8.50
	RCFL-H*3621(ROLA-115E05)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,200 [566]	36,200 [10.6]	3.90	23,200 [6.8]	2.70	8.50
	RHKL-HM3617(RCSL-H*3617)	36,000 [10.5]	26,300 [7.7]	9,700 [2.8]	12.50	15.00	74	1,225 [578]	37,200 [10.9]	3.98	24,200 [7.1]	2.80	9.00
RHSL-HM3617(RCSL-H*3617)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	12.00	14.50	74	1,200 [566]	37,600 [11.0]	3.84	24,600 [7.2]	2.70	8.20	
RHSL-HM3621(RCSL-H*3621)	35,600 [10.4]	25,900 [7.6]	9,700 [2.8]	11.50	14.00	74	1,200 [566]	37,600 [11.0]	3.82	24,600 [7.2]	2.70	8.20	
037JEZ	RHLL-HM3617(RCSL-H*3617) ①	36,600 [10.7]	26,450 [7.7]	10,150 [3.0]	12.50	15.00	74	1,150 [543]	34,400 [10.1]	3.68	22,600 [6.6]	2.60	9.00
	RCFL-H*3617(RGGE-06?MCK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,800 [10.2]	3.58	23,000 [6.7]	2.54	8.50
	RCFL-H*3617(RGJF-06?MCK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,800 [10.2]	3.58	23,000 [6.7]	2.54	8.50
	RCFL-H*3617(RGLE-07?AMK?)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,600 [10.1]	3.60	22,800 [6.7]	2.56	8.50
	RCFL-H*3617(RGLT-07?AMK?)	36,600 [10.7]	26,500 [7.8]	10,100 [3.0]	12.50	15.00	74	1,150 [543]	33,600 [9.8]	3.62	21,800 [6.4]	2.52	9.00
	RCFL-H*3617(RGPE-05?BMK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,800 [10.2]	3.56	23,000 [6.7]	2.52	8.50
	RCFL-H*3617(RGPE-07?AMK?)	36,600 [10.7]	26,800 [7.9]	9,800 [2.9]	11.50	14.00	74	1,225 [578]	34,800 [10.2]	3.58	23,000 [6.7]	2.54	8.50

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
													Rev. 5/4/2012
	RCFL-H*3617(RHWB-04WMX36A)	36,800 [10.8]	26,500 [7.8]	10,300 [3.0]	12.00	14.50	74	1,150 [543]	35,000 [10.3]	3.68	23,200 [6.8]	2.62	8.50
	RCFL-H*3617(RHWB-06WMX48A)	36,800 [10.8]	26,500 [7.8]	10,300 [3.0]	12.00	14.50	74	1,150 [543]	35,200 [10.3]	3.65	23,200 [6.8]	2.60	8.50
	RCFL-H*3617(ROCA-070E03)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,600 [10.1]	3.60	22,800 [6.7]	2.56	8.50
	RCFL-H*3617(ROCA-070E04)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,600 [10.1]	3.60	22,800 [6.7]	2.56	8.50
	RCFL-H*3617(ROLA-070E03)	36,400 [10.7]	26,300 [7.7]	10,100 [3.0]	12.00	14.50	74	1,175 [554]	34,400 [10.1]	3.66	22,600 [6.6]	2.60	8.50
	RCFL-H*3617(ROLA-070E04)	36,400 [10.7]	26,300 [7.7]	10,100 [3.0]	12.00	14.50	74	1,175 [554]	34,400 [10.1]	3.66	22,600 [6.6]	2.60	8.50
	RCFL-H*3617+RXMD-C04	35,800 [10.5]	25,300 [7.4]	10,500 [3.1]	11.50	14.00	74	1,075 [507]	33,600 [9.8]	3.60	21,600 [6.3]	2.50	8.50
	RCFL-H*3621(RGFE-09?ZCM?)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	34,600 [10.1]	3.64	22,800 [6.7]	2.58	8.50
	RCFL-H*3621(RGFE-10?ZCM?)	36,600 [10.7]	26,800 [7.9]	9,800 [2.9]	11.50	14.00	74	1,225 [578]	34,600 [10.1]	3.62	22,800 [6.7]	2.56	8.50
	RCFL-H*3621(RGFG-09?ZCM?)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	34,600 [10.1]	3.64	22,800 [6.7]	2.58	8.50
	RCFL-H*3621(RGFG-10?ZCM?)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,600 [10.1]	3.62	22,800 [6.7]	2.56	8.50
	RCFL-H*3621(RGGE-06?MCK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,800 [10.2]	3.58	23,000 [6.7]	2.54	8.50
	RCFL-H*3621(RGGE-07?MCK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,800 [10.2]	3.56	23,000 [6.7]	2.52	8.50
037JEZ	RCFL-H*3621(RGGE-09?ZCM?)	36,800 [10.8]	27,000 [7.9]	9,800 [2.9]	12.00	14.50	74	1,225 [578]	34,600 [10.1]	3.66	22,600 [6.6]	2.58	8.50
	RCFL-H*3621(RGGE-10?ZCM?)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	34,600 [10.1]	3.64	22,800 [6.7]	2.58	8.50
	RCFL-H*3621(RGJF-06?MCK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,800 [10.2]	3.58	23,000 [6.7]	2.54	8.50
	RCFL-H*3621(RGJF-07?MCK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,800 [10.2]	3.56	23,000 [6.7]	2.52	8.50
	RCFL-H*3621(RGJF-09?ZCM?)	36,800 [10.8]	27,000 [7.9]	9,800 [2.9]	12.00	14.50	74	1,225 [578]	34,600 [10.1]	3.66	22,600 [6.6]	2.58	8.50
	RCFL-H*3621(RGJF-10?ZCM?)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	34,600 [10.1]	3.64	22,800 [6.7]	2.58	8.50
	RCFL-H*3621(RGLE-07?AMK?)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,600 [10.1]	3.62	22,800 [6.7]	2.56	8.50
	RCFL-H*3621(RGLE-07?BRQ?)	37,000 [10.8]	27,200 [8.0]	9,800 [2.9]	12.00	14.50	74	1,225 [578]	34,400 [10.1]	3.68	22,600 [6.6]	2.60	8.50
	RCFL-H*3621(RGLE-10?BRM?)	37,000 [10.8]	27,100 [7.9]	9,900 [2.9]	12.50	15.00	74	1,200 [566]	33,600 [9.8]	3.64	21,800 [6.4]	2.54	9.00
	RCFL-H*3621(RGLT-07?AMK?)	36,600 [10.7]	26,500 [7.8]	10,100 [3.0]	12.50	15.00	74	1,150 [543]	33,600 [9.8]	3.62	21,800 [6.4]	2.54	9.00
	RCFL-H*3621(RGLT-07?BRQ?)	36,800 [10.8]	26,900 [7.9]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	34,400 [10.1]	3.68	22,600 [6.6]	2.60	8.50
	RCFL-H*3621(RGLT-10?BRM?)	36,600 [10.7]	26,500 [7.8]	10,100 [3.0]	12.00	14.50	74	1,175 [554]	33,600 [9.8]	3.60	21,600 [6.3]	2.50	8.50
	RCFL-H*3621(RGPE-05?BMK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,800 [10.2]	3.58	23,000 [6.7]	2.54	8.50
	RCFL-H*3621(RGPE-07?AMK?)	36,600 [10.7]	26,800 [7.9]	9,800 [2.9]	11.50	14.00	74	1,225 [578]	34,800 [10.2]	3.60	22,800 [6.7]	2.54	8.50
	RCFL-H*3621(RGPE-07?BRQ?)	37,000 [10.8]	27,200 [8.0]	9,800 [2.9]	12.00	14.50	74	1,225 [578]	33,600 [9.8]	3.60	21,600 [6.3]	2.50	8.50

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)					
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF	
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP		
Rev. 5/4/2012	RCFL-H*3621(RGPE-10?BRM?)	37,000 [10.8]	27,200 [8.0]	9,800 [2.9]	12.00	14.50	74	1,225 [578]	33,600 [9.8]	3.60	21,800 [6.4]	2.52	8.50	
	RCFL-H*3621(RGPT-05?BMK?)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	35,000 [10.3]	3.54	23,000 [6.7]	2.52	8.50	
	RCFL-H*3621(RGPT-07?AMK?)	36,600 [10.7]	26,500 [7.8]	10,100 [3.0]	12.00	14.50	74	1,150 [543]	34,400 [10.1]	3.68	22,600 [6.6]	2.60	8.50	
	RCFL-H*3621(RGPT-10?BRM?)	36,600 [10.7]	26,500 [7.8]	10,100 [3.0]	12.50	15.00	74	1,175 [554]	33,600 [9.8]	3.62	21,800 [6.4]	2.52	9.00	
	RCFL-H*3621(RGRM-09?ZAJ?)	36,600 [10.7]	26,800 [7.9]	9,800 [2.9]	11.50	14.00	74	1,225 [578]	34,800 [10.2]	3.58	23,000 [6.7]	2.54	8.50	
	RCFL-H*3621(RGRM-10?ZAJ?)	36,400 [10.7]	26,300 [7.7]	10,100 [3.0]	11.50	14.00	74	1,150 [543]	34,600 [10.1]	3.62	22,800 [6.7]	2.56	8.50	
	RCFL-H*3621(RGTM-07?RBG?)	36,600 [10.7]	26,500 [7.8]	10,100 [3.0]	12.50	15.00	74	1,125 [531]	33,600 [9.8]	3.62	21,800 [6.4]	2.54	9.00	
	RCFL-H*3621(RGTM-09?ZAJ?)	36,800 [10.8]	27,000 [7.9]	9,800 [2.9]	12.00	14.50	74	1,225 [578]	34,600 [10.1]	3.64	22,800 [6.7]	2.58	8.50	
	RCFL-H*3621(RHWB-04WMX36A)	37,000 [10.8]	26,700 [7.8]	10,300 [3.0]	12.00	14.50	74	1,150 [543]	35,000 [10.3]	3.68	23,200 [6.8]	2.62	8.50	
	RCFL-H*3621(RHWB-06WMX48A)	37,000 [10.8]	26,800 [7.9]	10,200 [3.0]	12.00	14.50	74	1,175 [554]	35,200 [10.3]	3.65	23,200 [6.8]	2.61	8.50	
	RCFL-H*3621(ROCA-070E03)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,600 [10.1]	3.62	22,800 [6.7]	2.56	8.50	
	RCFL-H*3621(ROCA-070E04)	36,600 [10.7]	26,700 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	34,600 [10.1]	3.62	22,800 [6.7]	2.56	8.50	
	RCFL-H*3621(ROLA-070E03)	36,400 [10.7]	26,300 [7.7]	10,100 [3.0]	12.00	14.50	74	1,175 [554]	34,400 [10.1]	3.68	22,600 [6.6]	2.60	8.50	
	RCFL-H*3621(ROLA-070E04)	36,400 [10.7]	26,300 [7.7]	10,100 [3.0]	12.00	14.50	74	1,175 [554]	34,400 [10.1]	3.68	22,600 [6.6]	2.60	8.50	
	RCFL-H*3621(ROLA-115E05)	36,800 [10.8]	26,900 [7.9]	9,900 [2.9]	12.00	14.50	74	1,200 [566]	33,600 [9.8]	3.60	21,600 [6.3]	2.50	8.50	
	RCFL-H*3621+RXMD-C04	35,800 [10.5]	25,300 [7.4]	10,500 [3.1]	11.50	14.00	74	1,075 [507]	33,600 [9.8]	3.60	21,600 [6.3]	2.50	8.50	
	037JEZ	RHKL-HM3617(RCSL-H*3617)	37,000 [10.8]	27,200 [8.0]	9,800 [2.9]	12.00	14.50	74	1,225 [578]	34,400 [10.1]	3.66	22,600 [6.6]	2.60	9.00
		RHSL-HM3617(RCSL-H*3617)	36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	35,000 [10.3]	3.54	23,000 [6.7]	2.52	8.50
RHSL-HM3621(RCSL-H*3621)		36,400 [10.7]	26,500 [7.8]	9,900 [2.9]	11.50	14.00	74	1,200 [566]	35,000 [10.3]	3.54	23,200 [6.8]	2.50	8.50	
RHLL-HM4821(RCSL-H*4821) ①		40,000 [11.7]	30,050 [8.8]	9,950 [2.9]	12.50	15.00	74	1,400 [661]	39,500 [11.6]	3.98	25,600 [7.5]	2.70	9.50	
RCFL-H*4821		39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	38,500 [11.3]	3.88	24,600 [7.2]	2.60	9.00	
RCFL-H*4821(RGFE-09?ZCM?)		39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.82	26,200 [7.7]	2.60	9.50	
RCFL-H*4821(RGFG-09?ZCM?)		39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.82	26,200 [7.7]	2.60	9.50	
RCFL-H*4821(RGFG-10?ZCM?)		39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.80	26,200 [7.7]	2.60	9.50	
RCFL-H*4821(RGGE-09?ZCM?)		39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.86	26,000 [7.6]	2.62	9.50	
RCFL-H*4821(RGGE-10?ZCM?)		39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.82	26,200 [7.7]	2.60	9.50	
042JEZ	RCFL-H*4821(RGJF-09?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.86	26,000 [7.6]	2.62	9.50	
	RCFL-H*4821(RGJF-10?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.82	26,000 [7.6]	2.60	9.50	
	RCFL-H*4821(RGLE-07?BRQ?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.90	25,800 [7.6]	2.64	9.50	

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*4821(RGLE-10?BRM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.94	25,800 [7.6]	2.68	9.50
	RCFL-H*4821(RGLT-07?AMK?)	39,500 [11.6]	29,100 [8.5]	10,400 [3.0]	12.00	14.50	74	1,325 [625]	39,500 [11.6]	3.92	25,800 [7.6]	2.66	9.50
	RCFL-H*4821(RGLT-07?BRQ?)	40,000 [11.7]	30,300 [8.9]	9,700 [2.8]	12.00	14.50	74	1,450 [684]	40,000 [11.7]	3.86	26,000 [7.6]	2.64	9.50
	RCFL-H*4821(RGLT-10?BRM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,425 [672]	39,500 [11.6]	3.88	26,000 [7.6]	2.64	9.50
	RCFL-H*4821(RGPE-07?BRQ?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.92	25,800 [7.6]	2.66	9.50
	RCFL-H*4821(RGPE-10?BRM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.92	25,800 [7.6]	2.66	9.50
	RCFL-H*4821(RGPT-07?AMK?)	39,500 [11.6]	29,100 [8.5]	10,400 [3.0]	12.00	14.50	74	1,325 [625]	39,500 [11.6]	3.88	26,000 [7.6]	2.64	9.50
	RCFL-H*4821(RGPT-07?BRQ?)	40,000 [11.7]	29,600 [8.7]	10,400 [3.0]	12.50	15.00	74	1,325 [625]	38,500 [11.3]	3.94	24,800 [7.3]	2.64	9.50
	RCFL-H*4821(RGPT-10?BRM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,425 [672]	39,500 [11.6]	3.90	25,800 [7.6]	2.64	9.50
	RCFL-H*4821(RGTM-06?MAE?)	38,500 [11.3]	27,700 [8.1]	10,800 [3.2]	11.50	14.00	74	1,225 [578]	40,000 [11.7]	3.86	26,200 [7.7]	2.62	9.50
042JEZ	RCFL-H*4821(RGTM-07?RBG?)	39,500 [11.6]	29,100 [8.5]	10,400 [3.0]	12.00	14.50	74	1,325 [625]	39,500 [11.6]	3.92	25,800 [7.6]	2.66	9.50
	RCFL-H*4821(RGTM-09?ZAJ?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.84	26,000 [7.6]	2.62	9.50
	RCFL-H*4821(RHWB-04WMX36A)	39,000 [11.4]	28,600 [8.4]	10,400 [3.0]	11.50	14.00	74	1,325 [625]	39,000 [11.4]	3.75	25,200 [7.4]	2.52	9.00
	RCFL-H*4821(RHWB-06WMX48A)	39,000 [11.4]	28,600 [8.4]	10,400 [3.0]	11.50	14.00	74	1,325 [625]	39,000 [11.4]	3.74	25,200 [7.4]	2.52	9.00
	RCFL-H*4821(ROLA-070E04)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,375 [649]	39,500 [11.6]	3.90	25,800 [7.6]	2.64	9.50
	RCFL-H*4821(ROLA-115E05)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.88	25,800 [7.6]	2.64	9.50
	RCFL-H*4824	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	38,500 [11.3]	3.88	24,600 [7.2]	2.60	9.00
	RCFL-H*4824(RGFE-09?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.80	26,200 [7.7]	2.60	9.50
	RCFL-H*4824(RGFE-12?RCM?)	40,000 [11.7]	30,300 [8.9]	9,700 [2.8]	11.50	14.00	74	1,450 [684]	40,000 [11.7]	3.84	26,000 [7.6]	2.62	9.50
	RCFL-H*4824(RGFG-09?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.80	26,200 [7.7]	2.60	9.50
	RCFL-H*4824(RGFG-10?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.80	26,200 [7.7]	2.60	9.50
	RCFL-H*4824(RGFG-12?RCM?)	40,000 [11.7]	30,300 [8.9]	9,700 [2.8]	11.50	14.00	74	1,450 [684]	40,000 [11.7]	3.84	26,000 [7.6]	2.62	9.50
	RCFL-H*4824(RGGE-09?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.86	26,000 [7.6]	2.62	9.50
	RCFL-H*4824(RGGE-10?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.82	26,200 [7.7]	2.60	9.50
	RCFL-H*4824(RGGE-12?RCM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,375 [649]	39,500 [11.6]	3.92	25,800 [7.6]	2.66	9.50
	RCFL-H*4824(RGJF-09?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.86	26,000 [7.6]	2.62	9.50
	RCFL-H*4824(RGJF-10?ZCM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.82	26,000 [7.6]	2.60	9.50
	RCFL-H*4824(RGJF-12?RCM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,375 [649]	39,500 [11.6]	3.92	25,800 [7.6]	2.66	9.50
RCFL-H*4824(RGLE-07?BRQ?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.90	25,800 [7.6]	2.64	9.50	

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*4824(RGLE-10?BRM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.94	25,800 [7.6]	2.68	9.50
	RCFL-H*4824(RGLE-12?ARM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,425 [672]	39,500 [11.6]	3.94	25,800 [7.6]	2.68	9.50
	RCFL-H*4824(RGLT-07?BRQ?)	40,000 [11.7]	30,300 [8.9]	9,700 [2.8]	12.00	14.50	74	1,450 [684]	40,000 [11.7]	3.86	26,000 [7.6]	2.64	9.50
	RCFL-H*4824(RGLT-10?BRM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,425 [672]	39,500 [11.6]	3.88	26,000 [7.6]	2.64	9.50
	RCFL-H*4824(RGLT-12?ARM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.50	15.00	74	1,375 [649]	39,500 [11.6]	3.94	25,600 [7.5]	2.68	9.50
	RCFL-H*4824(RGPE-07?BRQ?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.90	25,800 [7.6]	2.66	9.50
	RCFL-H*4824(RGPE-10?BRM?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.90	25,800 [7.6]	2.66	9.50
	RCFL-H*4824(RGPE-12?ARM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,425 [672]	39,500 [11.6]	3.94	25,800 [7.6]	2.66	9.50
	RCFL-H*4824(RGPT-07?BRQ?)	40,000 [11.7]	29,600 [8.7]	10,400 [3.0]	12.50	15.00	74	1,325 [625]	38,500 [11.3]	3.94	24,800 [7.3]	2.64	9.50
	RCFL-H*4824(RGPT-10?BRM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.00	14.50	74	1,425 [672]	39,500 [11.6]	3.90	25,800 [7.6]	2.64	9.50
	RCFL-H*4824(RGPT-12?ARM?)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.50	15.00	74	1,375 [649]	39,500 [11.6]	3.96	25,600 [7.5]	2.68	9.50
	RCFL-H*4824(RGRM-12?RAJ?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,425 [672]	40,000 [11.7]	3.84	26,000 [7.6]	2.60	9.50
	RCFL-H*4824(RGTM-07?RBG?)	39,500 [11.6]	29,100 [8.5]	10,400 [3.0]	12.00	14.50	74	1,325 [625]	39,500 [11.6]	3.92	25,800 [7.6]	2.66	9.50
	RCFL-H*4824(RGTM-09?ZAJ?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	14.00	74	1,400 [661]	40,000 [11.7]	3.84	26,000 [7.6]	2.62	9.50
	RCFL-H*4824(RGTM-10?RBJ?)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,425 [672]	39,500 [11.6]	3.88	25,800 [7.6]	2.64	9.50
	RCFL-H*4824(RHWB-08WRX60A)	40,000 [11.7]	30,300 [8.9]	9,700 [2.8]	12.00	14.50	74	1,450 [684]	39,000 [11.4]	3.81	25,000 [7.3]	2.55	9.00
	RCFL-H*4824(RHWB-10WRX60A)	40,000 [11.7]	29,800 [8.7]	10,200 [3.0]	12.50	15.00	74	1,350 [637]	38,500 [11.3]	3.88	24,600 [7.2]	2.60	9.00
	RCFL-H*4824(ROLA-070E04)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,375 [649]	39,500 [11.6]	3.90	25,800 [7.6]	2.64	9.50
	RCFL-H*4824(ROLA-115E05)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	12.00	14.50	74	1,400 [661]	39,500 [11.6]	3.88	26,000 [7.6]	2.64	9.50
	RHKL-HM4821(RCSL-H*4821)	40,000 [11.7]	30,100 [8.8]	9,900 [2.9]	12.50	15.00	74	1,400 [661]	39,500 [11.6]	3.96	25,600 [7.5]	2.68	9.50
RHSL-HM4221(RCSL-H*4821)	39,500 [11.6]	29,600 [8.7]	9,900 [2.9]	11.50	13.50	74	1,400 [661]	40,500 [11.9]	3.74	26,400 [7.7]	2.56	9.00	
048JEZ	RHLL-HM4821(RCSL-H*4821) ①	45,500 [13.3]	35,000 [10.3]	10,600 [3.1]	12.50	15.00	74	1,600 [755]	45,500 [13.3]	3.76	29,200 [8.6]	2.44	8.50
	RCFL-H*4821	44,500 [13.0]	33,200 [9.7]	11,300 [3.3]	11.50	14.00	74	1,475 [696]	44,500 [13.0]	3.49	28,400 [8.3]	2.22	8.20
	RCFL-H*4821(RGFE-09?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.58	29,400 [8.6]	2.33	8.20
	RCFL-H*4821(RGFE-10?ZCM?)	44,000 [12.9]	32,400 [9.5]	11,600 [3.4]	11.50	14.00	74	1,425 [672]	45,500 [13.3]	3.58	29,400 [8.6]	2.31	8.20
	RCFL-H*4821(RGFG-09?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.58	29,400 [8.6]	2.33	8.20
	RCFL-H*4821(RGFG-10?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.57	29,400 [8.6]	2.33	8.20
	RCFL-H*4821(RGGE-09?ZCM?)	44,500 [13.0]	33,000 [9.7]	11,500 [3.4]	11.50	14.00	74	1,400 [661]	45,500 [13.3]	3.65	29,400 [8.6]	2.36	8.20
	RCFL-H*4821(RGGE-10?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.58	29,400 [8.6]	2.33	8.20

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*4821(RGJF-09?ZCM?)	44,500 [13.0]	33,000 [9.7]	11,500 [3.4]	11.50	14.00	74	1,400 [661]	45,500 [13.3]	3.66	29,400 [8.6]	2.37	8.20
	RCFL-H*4821(RGJF-10?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.59	29,200 [8.6]	2.32	8.20
	RCFL-H*4821(RGLE-07?BRQ?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.00	14.50	74	1,400 [661]	45,500 [13.3]	3.70	29,200 [8.6]	2.38	8.20
	RCFL-H*4821(RGLE-10?BRM?)	45,500 [13.3]	33,500 [9.8]	12,000 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.76	29,400 [8.6]	2.43	8.50
	RCFL-H*4821(RGLT-07?AMK?)	44,500 [13.0]	32,900 [9.6]	11,600 [3.4]	11.50	14.00	74	1,425 [672]	45,500 [13.3]	3.66	29,400 [8.6]	2.37	8.20
	RCFL-H*4821(RGLT-07?BRQ?)	44,500 [13.0]	32,900 [9.6]	11,600 [3.4]	12.50	15.00	74	1,425 [672]	45,000 [13.2]	3.66	29,200 [8.6]	2.37	8.50
	RCFL-H*4821(RGLT-10?BRM?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.72	29,200 [8.6]	2.39	8.50
	RCFL-H*4821(RGPE-07?BRQ?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.72	29,200 [8.6]	2.39	8.50
	RCFL-H*4821(RGPE-10?BRM?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.72	29,200 [8.6]	2.39	8.50
	RCFL-H*4821(RGPT-07?BRQ?)	45,500 [13.3]	33,600 [9.8]	11,900 [3.5]	12.50	15.00	74	1,425 [672]	46,000 [13.5]	3.77	29,600 [8.7]	2.43	8.50
048JEZ	RCFL-H*4821(RGPT-10?BRM?)	45,000 [13.2]	33,200 [9.7]	11,800 [3.5]	12.50	15.00	74	1,425 [672]	45,500 [13.3]	3.74	29,200 [8.6]	2.41	8.50
	RCFL-H*4821(RGRM-09?ZAJ?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	46,000 [13.5]	3.62	29,600 [8.7]	2.34	8.20
	RCFL-H*4821(RGRM-10?ZAJ?)	45,000 [13.2]	33,000 [9.7]	12,000 [3.5]	11.50	14.00	74	1,425 [672]	46,500 [13.6]	3.64	30,200 [8.8]	2.36	8.20
	RCFL-H*4821(RGTM-07?RBG?)	44,500 [13.0]	33,000 [9.7]	11,500 [3.4]	11.50	14.00	74	1,475 [696]	45,000 [13.2]	3.59	29,400 [8.6]	2.34	8.20
	RCFL-H*4821(RGTM-09?ZAJ?)	44,500 [13.0]	33,000 [9.7]	11,500 [3.4]	11.50	14.00	74	1,400 [661]	45,500 [13.3]	3.65	29,400 [8.6]	2.37	8.20
	RCFL-H*4821(ROCA-070E04)	44,500 [13.0]	32,500 [9.5]	12,000 [3.5]	12.00	14.00	74	1,400 [661]	46,500 [13.6]	3.65	30,000 [8.8]	2.36	8.20
	RCFL-H*4821(ROLA-070E04)	45,000 [13.2]	32,800 [9.6]	12,200 [3.6]	12.00	14.00	74	1,375 [649]	46,000 [13.5]	3.74	29,600 [8.7]	2.41	8.20
	RCFL-H*4821(ROLA-115E05)	44,500 [13.0]	32,800 [9.6]	11,700 [3.4]	12.00	14.50	74	1,400 [661]	45,500 [13.3]	3.69	29,200 [8.6]	2.37	8.20
	RCFL-H*4824	44,500 [13.0]	33,200 [9.7]	11,300 [3.3]	11.50	14.00	74	1,475 [696]	44,500 [13.0]	3.49	28,400 [8.3]	2.22	8.20
	RCFL-H*4824(RGFE-09?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.57	29,400 [8.6]	2.33	8.20
	RCFL-H*4824(RGFE-10?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,425 [672]	45,500 [13.3]	3.57	29,400 [8.6]	2.30	8.20
	RCFL-H*4824(RGFE-12?RCM?)	44,500 [13.0]	33,000 [9.7]	11,500 [3.4]	11.50	14.00	74	1,450 [684]	45,000 [13.2]	3.61	29,200 [8.6]	2.34	8.20
	RCFL-H*4824(RGFG-09?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.57	29,400 [8.6]	2.33	8.20
	RCFL-H*4824(RGFG-10?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,500 [13.3]	3.60	29,400 [8.6]	2.32	8.20
	RCFL-H*4824(RGFG-12?RCM?)	44,500 [13.0]	33,000 [9.7]	11,500 [3.4]	11.50	14.00	74	1,450 [684]	45,000 [13.2]	3.61	29,200 [8.6]	2.34	8.20
	RCFL-H*4824(RGGE-09?ZCM?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,500 [13.3]	3.65	29,400 [8.6]	2.36	8.20
	RCFL-H*4824(RGGE-10?ZCM?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.58	29,400 [8.6]	2.33	8.20
	RCFL-H*4824(RGGE-12?RCM?)	44,500 [13.0]	32,500 [9.5]	12,000 [3.5]	12.50	15.00	74	1,375 [649]	45,500 [13.3]	3.73	29,200 [8.6]	2.40	8.50
	RCFL-H*4824(RGJF-09?ZCM?)	44,500 [13.0]	32,500 [9.5]	12,000 [3.5]	11.50	14.00	74	1,400 [661]	45,500 [13.3]	3.66	29,400 [8.6]	2.37	8.20

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RCFL-H*4824(RGJF-10?ZCM?)	44,000 [12.9]	32,300 [9.5]	11,700 [3.4]	11.50	14.00	74	1,400 [661]	45,000 [13.2]	3.59	29,200 [8.6]	2.32	8.20
	RCFL-H*4824(RGJF-12?RCM?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.50	15.00	74	1,375 [649]	45,500 [13.3]	3.73	29,200 [8.6]	2.40	8.50
	RCFL-H*4824(RGLE-07?BRQ?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.00	14.50	74	1,400 [661]	45,500 [13.3]	3.70	29,200 [8.6]	2.38	8.20
	RCFL-H*4824(RGLE-10?BRM?)	45,500 [13.3]	33,500 [9.8]	12,000 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.76	29,400 [8.6]	2.43	8.50
	RCFL-H*4824(RGLE-12?ARM?)	45,000 [13.2]	33,200 [9.7]	11,800 [3.5]	12.50	15.00	74	1,425 [672]	45,500 [13.3]	3.75	29,200 [8.6]	2.41	8.50
	RCFL-H*4824(RGLT-07?BRQ?)	44,500 [13.0]	33,000 [9.7]	11,500 [3.4]	12.50	15.00	74	1,425 [672]	45,000 [13.2]	3.66	29,200 [8.6]	2.37	8.50
	RCFL-H*4824(RGLT-10?BRM?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.72	29,200 [8.6]	2.39	8.50
	RCFL-H*4824(RGPE-07?BRQ?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.71	29,200 [8.6]	2.39	8.50
	RCFL-H*4824(RGPE-10?BRM?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.71	29,200 [8.6]	2.39	8.50
	RCFL-H*4824(RGPE-12?ARM?)	45,000 [13.2]	33,200 [9.7]	11,800 [3.5]	12.50	15.00	74	1,425 [672]	45,500 [13.3]	3.74	29,200 [8.6]	2.41	8.50
048JEZ	RCFL-H*4824(RGPT-07?BRQ?)	45,500 [13.3]	33,700 [9.9]	11,800 [3.5]	12.50	15.00	74	1,425 [672]	46,000 [13.5]	3.77	29,600 [8.7]	2.43	8.50
	RCFL-H*4824(RGPT-10?BRM?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.50	15.00	74	1,400 [661]	45,500 [13.3]	3.73	29,200 [8.6]	2.40	8.50
	RCFL-H*4824(RGRM-09?ZAJ?)	44,000 [12.9]	32,200 [9.4]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	46,000 [13.5]	3.62	29,600 [8.7]	2.33	8.20
	RCFL-H*4824(RGRM-10?ZAJ?)	45,000 [13.2]	33,000 [9.7]	12,000 [3.5]	11.50	14.00	74	1,425 [672]	46,500 [13.6]	3.64	30,200 [8.8]	2.36	8.20
	RCFL-H*4824(RGRM-12?RAJ?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	11.50	14.00	74	1,425 [672]	45,500 [13.3]	3.65	29,400 [8.6]	2.36	8.20
	RCFL-H*4824(RGTM-07?RBG?)	44,500 [13.0]	33,000 [9.7]	11,500 [3.4]	11.50	14.00	74	1,475 [696]	45,000 [13.2]	3.59	29,400 [8.6]	2.34	8.20
	RCFL-H*4824(RGTM-09?ZAJ?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	11.50	14.00	74	1,400 [661]	45,500 [13.3]	3.65	29,400 [8.6]	2.37	8.20
	RCFL-H*4824(RGTM-10?RBJ?)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.00	14.50	74	1,425 [672]	45,500 [13.3]	3.69	29,200 [8.6]	2.38	8.20
	RCFL-H*4824(RHWB-08WRX60A)	45,500 [13.3]	34,000 [10.0]	11,500 [3.4]	12.50	15.00	74	1,450 [684]	46,000 [13.5]	3.85	29,600 [8.7]	2.49	8.50
	RCFL-H*4824(RHWB-10WRX60A)	45,500 [13.3]	34,000 [10.0]	11,500 [3.4]	12.50	15.00	74	1,475 [696]	46,000 [13.5]	3.86	29,600 [8.7]	2.50	8.50
	RCFL-H*4824(ROCA-070E04)	44,500 [13.0]	32,500 [9.5]	12,000 [3.5]	11.50	14.00	74	1,400 [661]	46,500 [13.6]	3.65	30,200 [8.8]	2.37	8.20
	RCFL-H*4824(ROLA-070E04)	44,500 [13.0]	32,500 [9.5]	12,000 [3.5]	12.00	14.50	74	1,375 [649]	45,500 [13.3]	3.70	29,200 [8.6]	2.38	8.20
	RCFL-H*4824(ROLA-115E05)	44,500 [13.0]	32,700 [9.6]	11,800 [3.5]	12.00	14.50	74	1,400 [661]	45,500 [13.3]	3.68	29,400 [8.6]	2.38	8.20
	RHKL-HM4821(RCSL-H*4821)	45,000 [13.2]	33,100 [9.7]	11,900 [3.5]	12.50	15.00	74	1,400 [661]	45,000 [13.2]	3.74	29,000 [8.5]	2.42	8.50
	RHSL-HM4821(RCSL-H*4821)	45,000 [13.2]	34,000 [10.0]	11,000 [3.2]	11.50	14.00	74	1,550 [731]	46,000 [13.5]	3.59	30,000 [8.8]	2.35	8.20
	RHSL-HM4824(RCSL-H*4821)	45,000 [13.2]	34,000 [10.0]	11,000 [3.2]	11.50	14.00	74	1,550 [731]	46,000 [13.5]	3.59	30,000 [8.8]	2.35	8.20
	RHKL-HM4824(RCSL-H*4824)	46,000 [13.5]	35,800 [10.5]	10,200 [3.0]	12.50	15.00	74	1,625 [767]	45,000 [13.2]	3.70	29,000 [8.5]	2.39	8.50
	RHLL-HM4824(RCSL-H*4824)	46,000 [13.5]	35,800 [10.5]	10,200 [3.0]	12.50	15.00	74	1,625 [767]	45,000 [13.2]	3.71	29,000 [8.5]	2.40	8.50
RHSL-HM4824(RCSL-H*4824)	45,500 [13.3]	35,150 [10.3]	10,350 [3.0]	11.50	14.00	74	1,525 [720]	46,500 [13.6]	3.66	30,000 [8.8]	2.40	8.50	

① Highest sales volume tested combination required by DOE test procedures.

[] Designates Metric Conversions

Performance Data AHRI Standard Conditions—RPQL- JEZ (cont.)

Note: Only these combinations of indoor/outdoor units are approved and any other combinations should not be used.

Model Numbers		AHRI Cooling Performance							AHRI Heating Performance (70°F [21°C] Indoor)				
		80°F [26.5°C] DB/67°F [19.5°C] WB Indoor Air 95°F [35°C] DB Outdoor Air							Outdoor Air 47°F [8.5°C] DB/ 43°F [6°C] WB DOE High Temp.		Outdoor Air 17°F [-8.5°C] DB/ 15°F [-9.5°C] WB DOE Low Temp.		DOE Region IV HSPF
Outdoor Unit RPQL-	Indoor Coil and/or Air Handler	Total Capacity BTU/H [kW]	Net Sens. BTU/H [kW]	Net Latent BTU/H [kW]	EER	SEER	Snd. Rate dB	Indoor CFM [L/s]	BTU/H [kW]	COP	BTU/H [kW]	COP	
Rev. 5/4/2012	RHLL-HM6024(RCSL-H*6024) ①	52,500 [15.4]	37,900 [11.1]	14,600 [4.3]	12.50	15.00	76	1,600 [755]	51,000 [14.9]	3.66	29,200 [8.6]	2.34	8.50
	RCFL-H*6024(RGFD-12?RCM?)	52,000 [15.2]	37,950 [11.1]	14,050 [4.1]	11.50	14.00	76	1,650 [779]	51,500 [15.1]	3.56	29,800 [8.7]	2.28	8.20
	RCFL-H*6024(RGGE-12?RCM?)	52,000 [15.2]	37,550 [11.0]	14,450 [4.2]	11.50	14.00	76	1,575 [743]	51,500 [15.1]	3.58	29,600 [8.7]	2.30	8.20
	RCFL-H*6024(RGJF-12?RCM?)	52,000 [15.2]	37,550 [11.0]	14,450 [4.2]	11.50	14.00	76	1,575 [743]	51,500 [15.1]	3.58	29,600 [8.7]	2.30	8.20
	RCFL-H*6024(RGLE-07?BRQ?)	52,000 [15.2]	37,600 [11.0]	14,400 [4.2]	11.50	14.00	76	1,600 [755]	51,500 [15.1]	3.56	29,800 [8.7]	2.28	8.20
	RCFL-H*6024(RGLE-10?BRM?)	52,000 [15.2]	37,550 [11.0]	14,450 [4.2]	12.00	14.50	76	1,600 [755]	51,500 [15.1]	3.62	29,600 [8.7]	2.32	8.20
	RCFL-H*6024(RGLE-12?ARM?)	52,000 [15.2]	37,550 [11.0]	14,450 [4.2]	12.00	14.50	76	1,600 [755]	51,500 [15.1]	3.62	29,600 [8.7]	2.32	8.20
	RCFL-H*6024(RGLT-12?ARM?)	52,500 [15.4]	38,800 [11.4]	13,700 [4.0]	11.50	14.00	76	1,700 [802]	51,500 [15.1]	3.56	29,800 [8.7]	2.28	8.20
	RCFL-H*6024(RGPE-07?BRQ?)	52,000 [15.2]	37,600 [11.0]	14,400 [4.2]	11.50	14.00	76	1,600 [755]	51,500 [15.1]	3.58	29,600 [8.7]	2.30	8.20
	RCFL-H*6024(RGPE-10?BRM?)	51,500 [15.1]	36,700 [10.8]	14,800 [4.3]	12.00	14.50	76	1,550 [731]	51,000 [14.9]	3.62	29,400 [8.6]	2.32	8.20
	RCFL-H*6024(RGPE-12?ARM?)	51,500 [15.1]	36,450 [10.7]	15,050 [4.4]	12.00	14.50	76	1,525 [720]	51,000 [14.9]	3.64	29,400 [8.6]	2.34	8.20
	RCFL-H*6024(RGPT-07?BRQ?)	52,000 [15.2]	37,100 [10.9]	14,900 [4.4]	12.00	14.50	76	1,550 [731]	51,000 [14.9]	3.66	29,200 [8.6]	2.34	8.20
	RCFL-H*6024(RGPT-10?BRM?)	52,000 [15.2]	38,350 [11.2]	13,650 [4.0]	11.50	14.00	76	1,700 [802]	51,500 [15.1]	3.54	30,000 [8.8]	2.28	8.20
	RCFL-H*6024(RGPT-12?ARM?)	52,500 [15.4]	38,800 [11.4]	13,700 [4.0]	11.50	14.00	76	1,700 [802]	51,500 [15.1]	3.56	29,800 [8.7]	2.28	8.20
	RCFL-H*6024(RGTM-07?RBG?)	51,000 [14.9]	35,700 [10.5]	15,300 [4.5]	12.00	14.00	76	1,475 [696]	51,500 [15.1]	3.60	29,600 [8.7]	2.30	8.50
	RCFL-H*6024(RHWB-08WRX60A)	52,000 [15.2]	37,800 [11.1]	14,200 [4.2]	11.50	14.00	76	1,650 [779]	50,500 [14.8]	3.51	28,400 [8.3]	2.20	8.20
	RCFL-H*6024(RHWB-10WRX60A)	52,500 [15.4]	38,700 [11.3]	13,800 [4.0]	12.00	14.50	76	1,700 [802]	50,500 [14.8]	3.51	28,400 [8.3]	2.21	8.20
	RCFL-H*6024(ROLA-115E05)	51,500 [15.1]	37,100 [10.9]	14,400 [4.2]	11.50	14.00	76	1,600 [755]	51,500 [15.1]	3.56	29,800 [8.7]	2.28	8.20
RCFL-H*6024+RXMD-C04	51,500 [15.1]	36,900 [10.8]	14,600 [4.3]	11.50	14.00	76	1,600 [755]	52,000 [15.2]	3.52	30,000 [8.8]	2.26	8.20	
RHKL-HM6024(RCSL-H*6024)	52,500 [15.4]	37,900 [11.1]	14,600 [4.3]	12.50	15.00	76	1,600 [755]	51,000 [14.9]	3.72	29,000 [8.5]	2.36	8.50	
060JEZ	RHLL-HM6024(RCSL-H*6024) ①	59,500 [17.4]	42,250 [12.4]	17,250 [5.1]	12.00	14.50	74	1,800 [849]	60,500 [17.7]	3.86	37,800 [11.1]	2.70	9.00
	RCFL-H*6024	58,000 [17.0]	40,000 [11.7]	18,000 [5.3]	11.50	13.50	74	1,675 [790]	59,500 [17.4]	3.61	36,600 [10.7]	2.22	8.20
	RCFL-H*6024(RGLT-10?BRM?)	59,500 [17.4]	43,000 [12.6]	16,500 [4.8]	11.50	13.50	74	1,875 [885]	62,000 [18.2]	3.63	39,000 [11.4]	2.29	8.20
	RHKL-HM6024(RCSL-H*6024)	59,500 [17.4]	42,250 [12.4]	17,250 [5.1]	12.00	14.50	74	1,800 [849]	60,500 [17.7]	3.90	37,600 [11.0]	2.74	9.00
	RHSL-HM6024(RCSL-H*6024)	58,500 [17.1]	41,500 [12.2]	17,000 [5.0]	11.00	13.00	74	1,800 [849]	61,500 [18.0]	3.58	39,000 [11.4]	2.28	8.20

① Highest sales volume tested combination required by DOE test procedures.


[] Designates Metric Conversions

Electrical and Physical Data: RPQL- JEZ

Model Number RPQL-	ELECTRICAL							PHYSICAL						
	Phase Frequency (Hz) Voltage (Volts)	Compressor		Fan Motor Full Load Amperes (FLA)	Minimum Circuit Capacity Amperes	Fuse or HACR Circuit Breaker		Outdoor Coil			Refrig. Per Circuit Oz. [g]	Weight		
		Rated Load Amperes (RLA)	Locked Rotor Amperes (LRA)			Minimum Amperes	Maximum Amperes	Face Area Sq. Ft. [m ²]	No. Rows	CFM [L/s]		Net Lbs. [kg]	Shipping Lbs. [kg]	
Rev. 10/13/11														
018JEZ	1-60-208/230	9/9	48	1.4	13/13	15/15	20/20	11 [1.02]	1	1925 [908]	85 [2410]	156 [70.8]	157.5 [70.8]	
024JEZ	1-60-208/230	13.5/13.5	58.3	1.4	19/19	25/25	30/30	13 [1.21]	1	1925 [908]	98 [2778]	156 [70.8]	176 [70.8]	
030JEZ	1-60-208/230	14.1/14.1	73	1.4	20/20	25/25	30/30	17.1 [1.59]	1	1925 [908]	120 [3402]	175 [79.4]	195.5 [79.4]	
036JEZ	1-60-208/230	17.5/17.5	79	1.4	24/24	30/30	40/40	17.1 [1.59]	2	3575 [1687]	194 [5500]	226 [102.5]	237.5 [102.5]	
037JEZ	1-60-208/230	17/17	79	1	22/22	30/30	35/35	23 [2.14]	1	3500 [1652]	144 [4082]	246 [111.6]	256 [111.6]	
042JEZ	1-60-208/230	17.9/17.9	112	1.4	24/24	30/30	40/40	23 [2.14]	2	3575 [1687]	208 [5897]	256 [116.1]	261 [116.1]	
048JEZ	1-60-208/230	19.9/19.9	109	1.7	27/27	35/35	45/45	23 [2.14]	2	3575 [1687]	231 [6549]	258 [117]	296 [117]	
056JEZ	1-60-208/230	21.4/21.4	135	2.8	30/30	35/35	50/50	23 [2.14]	2	3100 [1463]	274 [7768]	300 [136.1]	304 [136.1]	
060JEZ	1-60-208/230	26.4/26.4	134	2.8	36/36	45/45	60/60	23 [2.14]	2	3100 [1463]	277 [7853]	300 [136.1]	304 [136.1]	

[] Designates Metric Conversions

Unit Dimensions



Model Number RPQL-	Height "H" (Inches) [mm]	Length "L" (Inches) [mm]	Width "W" (Inches) [mm]
018JEZ	19 [482]	40 1/2 [1028]	27 5/8 [701]
024JEZ	19 [482]	44 3/8 [1127]	31 1/2 [800]
030JEZ/036JEZ/037JEZ/042JEZ	33 [838]	44 3/8 [1127]	31 1/2 [800]
048JEZ/056JEZ/060JEZ	33 [838]	44 3/8 [1127]	31 1/2 [800]

Heat Pump Refrigerant Line Size Information

System Capacity	Line Size Connection Size (Inch I.D.) [mm]	Line Size (Inch O.D.) [mm]	Liquid Line Sizing (R-410A) Outdoor Unit Above or Below Indoor Coil (Heat Pumps Only)					
			Total Equivalent Length—Feet [m]					
			25 [7.62]	50 [15.24]	75 [22.86]	100 [30.48]	125 [38.10]	150 [45.72]
Maximum Vertical Separation—Feet [m]								
1 1/2 Ton	3/8" [9.53]	1/4 [6.35]	25 [7.62]	40 [12.19]	25 [7.62]	9 [2.74]	N/A	N/A
		5/16 [7.94]	25 [7.62]	50 [15.24]	62 [18.90]	58 [17.68]	53 [16.15]	49 [14.94]
		3/8* [9.53]	25 [7.62]	50 [15.24]	75 [22.86]	72 [21.95]	70 [21.34]	68 [20.73]
2 Ton	3/8" [9.53]	1/4 [6.35]	23 [7.01]	N/A	N/A	N/A	N/A	N/A
		5/16 [7.94]	25 [7.62]	36 [10.97]	29 [8.84]	23 [7.01]	16 [4.88]	9 [2.74]
		3/8* [9.53]	25 [7.62]	50 [15.24]	72 [21.95]	70 [21.34]	68 [20.73]	65 [19.81]
2 1/2 Ton	3/8" [9.53]	1/4 [6.35]	25 [7.62]	N/A	N/A	N/A	N/A	N/A
		5/16 [7.94]	25 [7.62]	49 [14.94]	38 [11.58]	27 [8.23]	17 [5.18]	6 [1.83]
		3/8* [9.53]	25 [7.62]	50 [15.24]	68 [20.73]	65 [19.81]	62 [18.90]	58 [17.68]
3 Ton	3/8" [9.53]	5/16 [7.94]	25 [7.62]	50 [15.24]	37 [11.28]	22 [6.71]	7 [2.13]	N/A
		3/8* [9.53]	25 [7.62]	50 [15.24]	68 [20.73]	63 [19.20]	58 [17.68]	53 [16.15]
3 1/2 Ton	3/8" [9.53]	5/16 [7.94]	25 [7.62]	23 [7.01]	4 [1.22]	N/A	N/A	N/A
		3/8* [9.53]	25 [7.62]	50 [15.24]	43 [13.11]	36 [10.97]	30 [9.14]	24 [7.32]
4 Ton	3/8" [9.53]	3/8* [9.53]	25 [7.62]	46 [14.02]	38 [11.58]	30 [9.14]	22 [6.71]	15 [4.57]
		1/2 [12.7]	25 [7.62]	50 [15.24]	56 [17.07]	55 [16.76]	53 [16.15]	52 [15.85]
5 Ton	3/8" [9.53]	3/8* [9.53]	25 [7.62]	50 [15.24]	56 [17.07]	44 [13.41]	32 [9.75]	20 [6.10]
		1/2 [12.7]	25 [7.62]	50 [15.24]	75 [22.86]	81 [24.69]	79 [24.08]	76 [23.16]

NOTES:

*Standard line size

N/A = Application not recommended.

[] Designates Metric Conversions

Heat Pump Refrigerant Line Size Information (cont.)

Suction Line Length/Size versus Capacity Multiplier (R-410A)								
Unit Size		1 1/2 Ton	2 Ton	2 1/2 Ton	3 Ton	3 1/2 Ton	4 Ton	5 Ton
Suction Line Connection Size	3/4" [19.05] I.D.				7/8" [22.23] I.D.			
Suction Line Run— Feet [m]	5/8" [15.88 mm] O.D. Opt. 3/4" [19.05 mm] O.D. Std.*		5/8" [15.88 mm] O.D. Opt. 3/4" [19.05 mm] O.D. Std.* 7/8" [22.23 mm] O.D. Opt.		3/4" [19.05 mm] O.D. Opt. 7/8" [22.23 mm] O.D. Std.*		7/8" [22.23 mm] O.D. Opt. 1 1/8" [28.58 mm] O.D. Std.*	
25' [7.62]	Optional Standard Optional	1.00 1.00 —	1.00 1.00 —	1.00 1.00 1.00	1.00 1.00 —	1.00 1.00 —	1.00 1.00 —	1.00 1.00 —
50' [15.24]	Optional Standard Optional	0.98 0.99 —	0.98 0.99 —	0.96 0.98 0.99	0.98 0.99 —	0.99 0.99 —	0.99 0.99 —	0.99 0.99 —
100' [30.48]	Optional Standard Optional	0.95 0.96 —	0.95 0.96 —	0.94 0.96 0.97	0.96 0.97 —	0.96 0.98 —	0.96 0.98 —	0.97 0.98 —
150' [45.72]	Optional Standard Optional	0.92 0.93 —	0.92 0.94 —	0.91 0.93 0.95	0.94 0.95 —	0.94 0.96 —	0.95 0.96 —	0.94 0.97 —

NOTES: NOTES:

*Standard line size

N/A = Using suction line larger than shown in chart will result in poor oil return and is not recommended.

[] Designates Metric Conversions

BEFORE PURCHASING THIS APPLIANCE, READ IMPORTANT ENERGY COST AND EFFICIENCY INFORMATION AVAILABLE FROM YOUR RETAILER.

GENERAL TERMS OF LIMITED WARRANTY

Rheem will furnish a replacement for any part of this product which fails in normal use and service within the applicable period stated, in accordance with the terms of the limited warranty.

For Complete Details of the Limited Warranty, Including Applicable Terms and Conditions, See Your Local Installer or Contact the Manufacturer for a Copy.

Compressor Ten (10) Years
Any Other Part Ten (10) Years

RPQL- JEZ Conditional Replacement Warranty:

Rheem will provide a replacement model (if an exact replacement is not available, an equivalent product will be provided) to the original purchaser if the compressor fails within 5 years (providing the unit is installed with a new Rheem Air Handler OR Rheem Indoor Coil with a Rheem Gas Furnace, and is properly matched as specified by Rheem as listed in the Air Conditioning Institute (AHRI) published rating, and if additional conditions are satisfied. See product warranty card for additional information.

Before proceeding with installation, refer to installation instructions packaged with each model, as well as complying with all Federal, State, Provincial, and Local codes, regulations, and practices.

**Rheem Heating,
Cooling and
Water Heating**

P.O. Box 17010, Fort Smith, AR 72917



"In keeping with its policy of continuous progress and product improvement, Rheem reserves the right to make changes without notice."